

ERT Log

July 1, 2022 - June 30 2023

#	Ref. #	Date	Type	Time	Response	Location	Cause
1	098/2022	July 4, 2022	Fire Alarm	12:49 PM	12:46 PM	Office 423d - IOEC	@ 12:49 PM - Suspected dust build-up might have activated alarm
2	099/2022	July 6, 2022	False Alarm	1:14 PM	1:15 PM	Mechanical Shaft B204 - OSB	@ 1:14 PM - Defective device activated alarm
3	0100/2022	July 13, 2022	Fire Alarm	4:01 PM	4:02 PM	Room 415a - Chemistry	@ 4:01 PM - Defective ballast Generated Fumes and Activated Alarm
4	0101/2022	July 16, 2022	False Alarm	6:20 PM	6:22 PM	F8 NW Waiting Area - ACC	@ 6:20 PM - Defective device activated alarm
5	0102/2022	July 18, 2022	Fire Alarm	1:08 PM	1:05 PM	On Call Room F349 - B56	@ 1:08 PM - Suspected dust might have activated alarm
6	0103/2022	July 20, 2022	Fire Alarm	3:09 PM	3:12 PM	Receiving Area E383 - PLM - AUBMC	@ 3:09 PM - Excessive Spray of disinfectant activated alarm
7	0104/2022	July 21, 2022	Fire Alarm	4:06 PM	4:07 PM	Store Room E126a - AUBMC	@ 4:06 PM - Generated Vapor from Kettle activated alarm
8	0105/2022	July 23, 2022	False Alarm	12:26 AM	12:30 AM	Exhaust fan Room B128 - OSB	@ 12:26 AM - Defective device activated alarm - Replaced
9	0106/2022	July 28, 2022	Fire Alarm	8:18 AM	8:20 AM	Mech Room W255r - AUBMC	@ 8:18 AM - Rectification of water leak activated alarm
10	0107/2022	July 30, 2022	Fire Alarm	1:16 PM	1:18 PM	F1 Lounge - Jewet Hall	@ 1:16 PM - Broken manual call point cover activated alarm
11	0108/2022	July 30, 2022	Fire Alarm	10:23 PM	10:25 PM	F4 Corridor - New Women	@ 10:23 PM - Overheated food item in Microwave activated alarm
12	0109/2022	July 31, 2022	False Alarm	1:50 PM	1:53 PM	F4 Corridor - SRB	@ 1:50 PM - Defective smoke detector base activated alarm
13	0110/2022	August 2, 2022	False Alarm	1:57 PM	1:56 PM	B2 Parking - East - IOEC	@ 1:57 PM - Defective detector base activated alarm
14	0111/2022	August 3, 2022	Fire Alarm	2:23 PM	2:22 PM	F3 & F7 Corridors - New Women (5 Alarms)	@ 2:23 PM - Heavy smoke generated by back-up Generators activated alarm
15	0112/2022	August 3, 2022	Fire Alarm	2:23 PM	2:24 PM	F1, F2 & F3 Corridors - FS1 (3 Alarms)	@ 2:23 PM - Heavy smoke generated by back-up Generators activated alarm
16	0113/2022	August 6, 2022	Fire Alarm	12:01 AM	12:04 AM	F2 Women Corridor - Kerr Hall	@ 12:04 AM - Suspected dust might have activated the alarm
17	0114/2022	August 8, 2022	Fire Alarm	6:49 AM	6:51 AM	F1 Toilet - New Women	@ 6:49 AM - Pesticides fumes activated alarm
18	0115/2022	August 11, 2022	False Alarm	8:14 PM	8:16 PM	Women Kitchen 501 - Kerr	@ 8:14 PM - Defective heat detector activated alarm - Replaced
19	0116/2022	August 11, 2022	False Alarm	10:13 PM	10:15 PM	Women Kitchen 501 - Kerr	@ 10:13 PM - Defective heat detector's base activated alarm - Replaced
20	0117/2022	August 12, 2022	Fire Alarm	11:46 AM	11:48 AM	Lounge 9024 - ACC	@ 11:46 AM - fumes from overheating bread in Microwave activated alarm
21	0118/2022	August 12, 2022	Fire	7:45 PM	7:48 PM	Incinerator Stack on Roof - AUBMC	@ 7:45 PM - Incineration product blocked stack leading to wet scrubber and ignited
22	0119/2022	August 13, 2022	Fire Alarm	8:32 AM	8:34 AM	CSD E152 - AUBMC	@ 8:32 AM - Steam from cart washer activated alarm
23	0120/2022	August 14, 2022	Fire Alarm	12:06 AM	12:08 AM	Padded Room F345 - Building 56	@ 12:06 AM - fumes from overheating Plastic cup in microwave activated alarm
24	0121/2022	August 15, 2022	Fire Alarm	8:09 PM	8:11 PM	Male Toilet E484 - AUBMC	@ 8:09 PM - smoking in toilet activated alarm
25	0122/2022	August 16, 2022	Fire Alarm	12:52 PM	12:52 PM	B DER - Murex	@ 12:52 PM - Agitated dust activated alarm
26	0123/2022	August 19, 2022	Fire Alarm	2:26 PM	2:28 PM	CSD Autoclave room E150d - AUBMC	@ 2:26 PM - Suspected steam generated by Auto-clave activated alarm
27	0124/2022	August 24, 2022	Fire Alarm	3:57 PM	3:58 PM	Kitchenette F309 - B56	@ 3:57 PM - overheating a piece of bread in the microwave activated alarm
28	0125/2022	August 25, 2022	Fire Alarm	7:22 PM	7:23 PM	Chemical Engineering Lab 302 - IOEC	@ 7:22 PM - Defective base activated alarm
29	0126/2022	August 27, 2022	Fire Alarm	8:00 AM	8:05 AM	Room W751b - AUBMC	@ 8:00 AM - Agitated dust activated alarm
30	0127/2022	August 30, 2022	False Alarm	8:41 AM	8:43 AM	Attic # 3 - Marquand House	@ 8:41 AM - Defective device activated alarm
31	0128/2022	August 30, 2022	Fire Alarm	10:32 PM	10:34 PM	F1 Kitchenette - Murex	@ 10:32 PM - Overheating Popcorn bag in Microwave activated alarm
32	0129/2022	August 31, 2022	False Alarm	12:15 AM	12:17 AM	Cooling Tower Area - Roof - DTS	@ 12:15 AM - Defective device activated alarm
33	0130/2022	September 1, 2022	Fire Alarm	6:32 AM	6:33 AM	B203 Pump Room - CAB	@ 6:32 AM - Condensation damaged base and activated alarm
34	0131/2022	September 1, 2022	False Alarm	8:18 AM	8:19 AM	Top of Roof - DTS	@ 8:18 AM - generated smoke from incinerator was reported as a fire
35	0132/2022	September 1, 2022	Fire Alarm	5:47 PM	5:47 PM	F2 Reading room - Jafet Library	@ 5:47 PM - Failure in Fan Coil unit activated alarm
36	0132a/2022	September 2, 2022	Trouble	7:30 PM	7:32 PM	FACP - Murex	@ 7:30 PM - Interruption of Uninterrupted power supply
37	0133/2022	September 2, 2022	Fire Alarm	9:17 PM	9:19 PM	EW SB Staff Elevator Lobby - AUBMC	@ 9:17 PM - Fumes from the cremator activated alarm
38	0134/2022	September 2, 2022	Fire Alarm	10:09 PM	10:11 PM	F4 DER 413 - OSB	@ 10:09 PM - condensation damaged smoke detector and activated alarm
39	0135/2022	September 3, 2022	Fire Alarm	1:50 AM	1:52 AM	F3 East Wing - HR - College Hall	@ 1:50 AM - Lack of cooling and humidity activated alarm
40	0136/2022	September 3, 2022	Fire Alarm	11:30 PM	11:32 PM	Administration Office - Wing A - Agriculture	@ 11:30 PM - Defective combined smoke and heat detector activated alarm
41	0137/2022	September 9, 2022	Fire Alarm	6:40 PM	6:41 PM	F1 Lobby - New Women	@ 6:40 PM - Tampering with MCP activated alarm
42	0138/2022	September 10, 2022	Fire Alarm	9:53 PM	9:55 PM	Kitchenette F309 - B56	@ 9:53 PM - Fumes from overheating popcorn bag in Microwave activated alarm
43	0139/2022	September 14, 2022	Fire Alarm	9:40 AM	9:41 AM	Lab 418 - Van Dyck	@ 9:41 AM - Flammable Liquid Vapor activated the alarm
44	0140/2022	September 15, 2022	Fire Alarm	12:45 AM	12:47 AM	F1 Lounge Kitchen - New Women	@ 12:45 AM - Generated fumes when overheating caramelized sugar activated alarm
45	0141/2022	September 16, 2022	Fire Alarm	5:07 PM	5:09 PM	SLH	@ 5:07 PM - Suspected might have activated alarm
46	0142/2022	September 20, 2022	Fire Alarm	11:21 AM	11:23 AM	Basement Elevator Lobby - Sawwaf	@ 11:21 AM - Dust from Sawwaf Parking project activated alarm
47	0143/2022	September 23, 2022	Fire Alarm	1:48 PM	1:50 PM	ADA Exit - Cafeteria - Ada Dodge	@ 1:48 PM - MCP was pulled by cafeteria manager which activated the alarm
48	0144/2022	September 23, 2022	Fire Alarm	6:01 PM	6:03 PM	F1 Café - ACC	@ 6:01 PM - Fumes generated by Café staff activated alarm
49	0145/2022	October 2, 2022	False Alarm	1:41 PM	1:43 PM	Multipurpose Hall 402 - West Hall	@ 1:41 PM - Defective device activated alarm
50	0146/2022	October 2, 2022	Fire Alarm	9:29 PM	9:31 PM	F4 DER 413 - OSB	@ 9:29 PM - condensation damaged smoke detector and activated alarm
51	0147/2022	October 5, 2022	Fire Alarm	12:35 AM	12:36 AM	Auditorium 106 - Architecture	@ 12:35 AM - Suspected dust might have activated alarm
52	0148/2022	October 7, 2022	Fire Alarm	11:08 AM	11:10 AM	CSD Autoclave room E150d - AUBMC	@ 11:08 AM - Suspected steam generated by Auto-clave activated alarm
53	0149/2022	October 11, 2022	Fire Alarm	7:47 AM	7:49 AM	F1 passageway to computer labs - Bliss Hall	@ 7:47 AM - Tampering with MCP activated alarm
54	0150/2022	October 21, 2022	Fire Alarm	3:09 PM	3:05 PM	B5 Parking - ACC	@ 3:05 PM - Heat detector activated the alarm
55	0151/2022	October 22, 2022	Fire Alarm	7:33 AM	7:36 AM	F1 FGD Lab Corridor - Sawwaf	@ 7:33 AM - Suspected dust might have activated alarm
56	0152/2022	October 23, 2022	Fire Alarm	1:55 AM	1:58 AM	Utility Room E567 - AUBMC	@ 1:55 AM - Generated fumes from overheating bread in Microwave activated alarm

ERT Log

July 1, 2022 - June 30 2023

#	Ref. #	Date	Type	Time	Response	Location	Cause
57	0153/2022	October 23, 2022	Fire Alarm	12:58 PM	1:22 PM	F1 FGD Lab Corridor - Sawwaf	@ 12:58 PM - Suspected duct might have activated alarm
58	0154/2022	October 25, 2022	Fire Alarm	2:05 PM	2:08 PM	Office AB322 - MAB	@ 2:05 PM - Dust generation and spraying of aerosol activated alarm
59	0155/2022	October 26, 2022	FIRE	12:36 PM	12:31 PM	Environmental Lab 128 - IOEC	@ 12:36 PM - Defective thermostat of overheated benzene in oil bath initiated a fire.
60	0156/2022	October 26, 2022	Fire Alarm	1:36 PM	1:33 PM	F2 Kitchen - Raymond Ghosn	@ 1:36 PM - Overheating food item with paper and aluminum wrapping activated alarm
61	0157/2022	October 26, 2022	Fire Alarm	8:28 PM	8:32 PM	Nursing Workroom 5040 - ACC	@ 8:28 PM - excessive spraying of Aerosol activated alarm
62	0158/2022	November 3, 2022	Fire Alarm	3:20 PM	3:22 PM	F1 Lobby - Penrose	@ 3:20 PM - Agitated dust detector activated alarm
63	0159/2022	November 4, 2022	Fire Alarm	12:43 AM	12:45 AM	F3 Oxygen Cylinders Room - SRB	@ 12:43 AM - Water floor from stuck urinal flush valve on F4 activated alarm
64	0160/2022	November 7, 2022	Fire Alarm	9:30PM	9:33 PM	Lockers Room E1071 - AUBMC	@ 9:30 PM - failure in a transformer generated fumes and activated alarm
65	0161/2022	November 10, 2022	Fire Alarm	11:58 AM	11:55 AM	Room E417 - AUBMC	@ 11:58 AM - Agitated dust while removing detector cover activated the alarm
66	0162/2022	November 11, 2022	Fire Alarm	9:29 AM	9:31 AM	F7 Corridor - OFF Campus Residence	@ 9:21 AM - Overhetaed oil on the stove generated fumes and activated alarm
67	0163/2022	November 12, 2022	Fire Alarm	12:10 AM	12:13 AM	EW F1 CSD Soiled Room - AUBMC	@ 12:13 AM - Steam from cart washer activated the alarm
68	0164/2022	November 12, 2022	Fire Alarm	7:47 AM	7:49 AM	F3 Corridor - Murex	@ 7:47 AM - Fumes from overheating food items in the microwave activated alarm
69	0164-a/2022	November 17, 2022	Fire Alarm	11:37 AM	11:39 AM	B5 Parking - ACC	@ 11:37 AM - Remounting a heat detector on a defective base activated alarm
70	0165/2022	November 18, 2022	Fire Alarm	11:32 AM	11:34 AM	Office 369 - OSB	@ 11:32 AM - Excessive spraying of Aerosol activated alarm
71	0166/2022	November 18, 2022	Fire Alarm	12:16 PM	12:17 PM	F1 Student Lounge - DTS	@ 12:16 PM - Overheated food in Microwave generated fumes & Activated alarm
72	0167/2022	November 20, 2022	Fire Alarm	12:25 PM	12:26 PM	F6 Corridor - Boustani	@ 12:25 PM - Overheated food in Microwave generated fumes & Activated alarm
73	0168/2022	November 25, 2022	Fire Alarm	5:40 PM	5:40 PM	F4 Corridor - DTS	@ 5:40 PM - Aerosol from disinfection activated alarm
74	0169/2022	November 26, 2022	Fire Alarm	10:16 AM	10:19 AM	F2 Outside washing room - Marquand House	@ 10:16 AM - Suspected steam for steam ironing device activated alarm
75	0170/2022	November 29, 2022	Fire Alarm	3:14 PM	3:15 PM	F1 Manual Call Point - Reynolds	@ 3:14 PM - A student tampered with MCP and Activated alarm
76	0171/2022	December 5, 2022	Fire Alarm	1:31 PM	1:33 PM	Mechanical Room B104 - Penrose	@ 1:31 PM - Condensation from uninsulated steam pipe activated alarm
77	0172/2022	December 6, 2022	Fire Alarm	8:57 AM	8:59 AM	Lab 417 - Van Dyck	@ 8:57 AM - Gas leak due to relocating a hood activated alarm
78	0173/2022	December 7, 2022	Fire Alarm	11:57 AM	11:59 AM	Room F506 - B56	@ 11:57 AM - Fumes from Burnt bread on hot plat activated alarm
79	0174/2022	December 8, 2022	Fire Alarm	12:59 PM	12:59 PM	PAU Waiting area E233 - AUBMC	@ 12:59 PM - Fumes from visitors cigarette activated alarm
80	0175/2022	December 9, 2022	Fire Alarm	3:58 PM	3:58 PM	Conference Room P302 - Building 23	@ 3:58 PM - Suspected agitated dust might have activated alarm
81	0176/2022	December 13, 2022	False Alarm	4:16 AM	4:18 AM	Palestine Land Studies Center B03 - West Hall	@ 4:16 AM - Defective combined detector activated alarm
82	0177/2022	December 19, 2022	Fire Alarm	11:09 AM	11:11 AM	F1 Corridor - Murex	@ 11:09 AM - Dust generated by PPD activated alarm
83	0178/2022	December 20, 2022	Fire Alarm	11:43 AM	11:45 AM	F2 Lobby WFS - B23	@ 11:43 AM - Pressure fluctuation in FF Network activated alarm
84	0179/2022	December 21, 2022	Fire Alarm	11:21 AM	11:22 AM	F1 Corridor - Bechtel	@ 11:22 AM - Generated water mist activated alarm
85	0180/2022	December 21, 2022	Fire Alarm	1:03 PM	1:05 PM	Kitchen E1062 - AUBMC	@ 1:03 PM - Generated dust by housekeeping activated alarm
86	0181/2022	December 21, 2022	Fire Alarm	3:02 PM	3:03 PM	F2 Entrance Lobby - SRB	@ 3:02 PM - Activation of MCP activated the alarm
87	0182/2022	December 26, 2022	Fire Alarm	10:35 AM	10:45 AM	Lockers Room E1071 - AUBMC	@ 10:35 AM - failure in a transformer generated fumes and activated alarm
88	0183/2022	December 27, 2022	False Alarm	10:01 AM	10:03 AM	F2 Kitchen - Boustani Hall	@ 10:01 AM - Defective device activated alarm
89	0184/2022	December 27, 2022	Fire Alarm	11:50 AM	11:52 AM	F5 DER - IOEC	@ 11:50 AM - Generated dust by contractor activated alarm
90	0185/2022	December 27, 2022	Fire Alarm	3:02 PM	3:05 PM	F5 Corridor - Off Campus Residence	@ 3:02 PM - generated dust by PPD staff activated alarm
91	0186/2022	December 30, 2023	Fire Alarm	11:52 AM	11:54 AM	F2 Lobby WFS - B23	@ 11:52 AM - Pressure fluctuation in FF Network activated alarm
92	001/2023	January 3, 2023	Fire Alarm	12:09 PM	12:10 PM	Patient Room F338 - B56	@ 12:09 PM - Patient broke sprinkler and flooded the unit with water
93	002/2023	January 5, 2023	Fire Alarm	11:00 AM	11:02 AM	Toilet AB222 - MAB	@ 11:00 AM - excessive spray of aerosol activated alarm
94	003/2023	January 7, 2023	Fire Alarm	4:33 PM	4:30 PM	Basketball courts - CHSC	@ 4:33 PM - activation of the manual call point by one of the staff activated alarm.
95	004/2023	January 9, 2023	Fire Alarm	2:34 PM	2:31 PM	Roof Machine Room - IOEC	@ 2:34 PM - agitated dust while installing the smoke detector activated the alarm.
96	005/2023	January 14, 2023	Fire Alarm	12:19 PM	12:19 PM	Mechanical Room - Murex	@ 12:19 PM - Steam Leak activated the alarm
97	006/2023	January 15, 2023	Fire Alarm	2:07 PM	2:09 PM	F1 Toilet - Building 37	@ 2:07 PM - Generated Vapor by Housekeeping staff activated alarm
98	007/2023	January 31, 2023	Fire Alarm	9:33 AM	9:34 PM	F1 Gym Equipment Room - CHSC	@ 9:33 AM - Dust generated by CHSC Staff activated alarm
99	008/2023	February 2, 2023	Fire Alarm	11:09 AM	11:11 AM	Gym Women's Toilet 3104 - CHSC	@ 11:09 AM - Suspected fumes/water vapors might have activated alarm
100	009/2023	February 5, 2023	Fire Alarm	10:58 AM	11:01 AM	BMT Shower - E869 - AUBMC	@ 11:00 AM - Suspected detergent droplets Spray activated alarm
101	010/2023	February 7, 2023	Fire Alarm	7:04 PM	7:06 PM	Nurses Lounge W452 - AUBMC	@ 7:04 PM - Fumes from overheating bread in microwave activated alarm
102	011/2023	February 10, 2023	Fire Alarm	11:11 AM	11:12 AM	Male Toilet 1041 - ACC	@ 11:11 AM - suspected dust might have activated the alarm
103	012/2023	February 13, 2023	False Alarm	7:07 AM	7:10 AM	Classroom 314 - Chemistry	@ 7:07 PM - Defective device activated alarm
104	013/2023	February 14, 2023	False Alarm	7:52 PM	7:53 PM	F1 Lobby - Jewet	@ 7:52 PM - Tampering with MCP cover was reported as a fire alarm
105	014/2023	February 15, 2023	Fire Alarm	7:17 AM	7:18 AM	CSD room E150b - AUBMC	@ 7:17 AM - Steam from Autoclave activated alarm
106	015/2023	February 17, 2023	Fire Alarm	3:50 PM	3:52 PM	B1 Service elevator Lobby and Corridor - ACC	@ 3:50 PM - Smohe and fumes generated by a defective car engine activated alarm
107	016/2023	February 19, 2023	False Alarm	5:01 AM	5:03 AM	Classroom 314 - Chemistry	@ 5:01 PM - Defective device activated alarm
108	017/2023	February 20, 2023	False Alarm	1:45 PM	1:43 PM	F2 South West - Zone 49 - College Hall	@ 1:45 PM - Suspected Defect in Zone electronic board might have activated alarm
109	018/2023	February 22, 2023	FIRE	6:42 AM	6:57 AM	F3 North Corridor - ACC	@ 6:42 AM - Suspected failure in Battery connections initiated the fire
110	019/2023	February 22, 2023	Fire Alarm	11:11 PM	11:15 PM	Lockers Room W779 - AUBMC	@ 11:11 PM - Fumes from a burnt bread in the microwave activated alarm
111	020/2023	February 23, 2023	Fire Alarm	3:09 PM	3:10 PM	5th Floor Stacks - Zone 114 - Jafet Library	@ 3:09 PM - Fire smoke from water proofing work on roof activated the alarm
112	021/2023	February 23, 2023	Fire Alarm	3:43 PM	3:44 PM	EVL Lab 307E - SRB	@ 3:43 PM - flammable vapors from adjacent hood activated alarm

ERT Log

July 1, 2022 - June 30 2023

#	Ref. #	Date	Type	Time	Response	Location	Cause
113	022/2023	February 27, 2023	Fire Alarm	6:38 AM	6:43 AM	Room 9001 - ACC	@ 6:38 AM - Suspected blown-up dust might have activated the fire alarm
114	023/2023	February 27, 2023	Fire Alarm	2:50 PM	2:51 PM	ER Kitchen WW - AUBMC	@ 2:50 PM - Fumes from Burnt item in the Microwave activated the alarm
115	024/2023	March 1, 2023	False Alarm	2:32 AM	2:37 AM	F9 Elevator Lobby - ACC	@ 2:32 AM - Defective device activated alarm
116	025/2023	March 1, 2023	Fire Alarm	5:43 AM	5:45 AM	F2 Stair 01 - OSB	@ 5:43 PM - Suspected dust might have activated the alarm
117	026/2023	March 3, 2023	Fire Alarm	11:01 PM	11:03 PM	Mechanical Room SAS B104 - Penrose	@ 11:01 PM- Suspected dust might have triggered the fire alarm
118	027/2023	March 13, 2023	Fire Alarm	2:35 PM	2:37 PM	F1 Café - ACC	@ 2:35 PM - Fumes from overheated sandwich activated alarm
119	028/2023	March 16, 2023	Fire alarm	5:33 PM	5:34 PM	EW F2 Cafeteria seating area E205 - AUBMC	@ 5:33 PM - fumes from overheated bread activated alarm
120	029/2023	March 20, 2023	Fire Alarm	1:44 PM	1:45 PM	Mechanical Room B136 - OSB	@ 1:44 PM - Defective device activated alarm - Replaced
121	030/2023	March 28, 2023	Fire Alarm	1:55 PM	1:55 PM	F3 Oxygen Cylinders Room - SRB	@ 1:55 PM - Water floor from Janitor Sink on F4 activated alarm
122	031/2023	March 31, 2023	Fire Alarm	3:37 PM	3:37 PM	Cafeteria Store B107 - IOEC	@ 3:37 PM - Water Vapor generation activated alarm
123	032/2023	April 7, 2023	Fire Alarm	2:55 AM	2:59 AM	Mechanical Room B011 - Ada Dodge Cafeteria	@ 2:55 AM - Condensation activated alarm
124	033/2023	April 10, 2023	Fire Alarm	4:34 AM	4:38 AM	F1 Corridor - Laydies Wing - Kerr	@ 4:34 AM - Fumes from over heating food items in Kitchen activated alarm in corridor
125	034/2023	April 11, 2023	Fire Alarm	11:09 AM	11:10 AM	B1 Female toilet - Biology	@ 11:09 AM - Generated fumes from water roofing activated alarm
126	035/2023	April 11, 2023	Fire Alarm	3:29 PM	3:31 PM	EB04e Female's Toilet - AUBMC	@ 3:29 PM - Excessive use of aerosol spray activated the alarm
127	036/2023	April 11, 2023	Fire Alarm	4:57 PM	4:58 PM	Room W548e - AUBMC	@ 4:57 PM - Fumigation of patient room activated the alarm
128	037/2023	April 15, 2023	False Alarm	1:53 AM	1:55 AM	Hot Water Tank Room - Kerr Hall	@ 1:53 AM - Defective Device - Replaced
129	038/2023	April 15, 2023	False Alarm	9:22 PM	9:24 PM	Roof Tower Calibration Room - DTS	@ 9:22 PM - Defective device activated alarm
130	039/2023	April 17, 2023	Fire Alarm	2:37 AM	2:42 AM	Linen Room E474 - AUBMC	@ 2:37 AM - Overheated food in the microwave activated alarm
131	040/2023	April 19, 2023	Fire Alarm	12:48 PM	12:58 PM	Lobby G419 - Sawwaf Building	@12:48 PM - Overheated food item in Microwave activated alarm
132	041/2023	April 26, 2023	Fire Alarm	8:19 AM	8:20 AM	Lebanese Grill Area - Ada Dodge Cafeteria	@ 8:19 AM - gas leak activated the alarm
133	042/2023	April 27, 2023	Fire Alarm	9:45 AM	9:47 AM	Lebanese Grill Area - Ada Dodge Cafeteria	@ 9:45 AM - gas leak activated the alarm
134	043/2023	April 28, 2023	Fire Alarm	9:14 AM	9:15 AM	Electrical Room B13 - West Hall	@ 9:14 AM - Defective device activated alarm
135	044/2023	May 2, 2023	Fire Alarm	5:18 PM	5:19 PM	Pool Equipment Room 2200a - CHSC	@ 5:18 PM - Fumes from Overheated food item in Microwave activated alarm
136	045/2023	May 10, 2023	Fire Alarm	6:59 AM	7:01 AM	Room 015 - Biology	@ 6:59 AM - Fumes from Overheated food item in Microwave activated alarm
137	046/2023	May 12, 2023	False Alarm	2:42 AM	2:44 AM	Roof-Near AHU #4 - OSB	@ 2:42 AM - Defective device activated alarm - Replaced
138		May 17, 2023	Fire Smell	6:22 PM	6:23 PM	Lad 405 - Chemistry	@ 6:22 PM - Smell from lab oven that was left ON
139	047/2023	May 19, 2023	Fire Alarm	11:02 AM	11:02 AM	F3 Corridor - New Women	@ 11:02 AM - Fumes and steam from pressure cooker activated alarm
140	048/2023	May 23, 2023	Fire Alarm	1:32 PM	1:34 PM	F3 emergency stair - Psychiatry - B56	@ 1:32 PM - Manual call point pulled by patient activated alarm
141	049/2023	May 26, 2023	Fire Alarm	5:45 PM	5:44 PM	EW F2 Cafeteria seating area E205 - AUBMC	@ 5:45 PM - Fumes from overheated bread burnt tissue @ activated alarm
142	050/2023	May 29, 2023	Fire Alarm	12:03 PM	12:05 PM	F7 Corridor - Off Campus Residence	@ 12:03 PM - Generated dust by contractor activated alarm
143	051/2023	June 3, 2023	Fire Alarm	11:08 AM	11:11 AM	Room W658 - AUBMC	@ 11:08 AM - Dust generated by contractor activated alarm
144		June 5, 2023	Fire Alarm	7:45 AM	7:46 AM	SAS 405 - Agriculture Wing B	@ 7:45 AM - Water leak from floor above activated the fire alarm
145	052/2023	June 7, 2023	Fire Alarm	8:33 AM	8:34 AM	F1 Men's Toilet 102 - FS2	@ 8:33 AM - Generated hot water vapor by Housekeeping activated alarm
146	053/2023	June 7, 2023	Fire Alarm	9:18 AM	9:19 AM	Activities Lockers room 1108 - CHSC	@ 9:18 AM - Dust generated by contractor in Basement activated alarm
147	054/2023	June 8, 2023	Fire Alarm	11:11 AM	11:09 AM	Housekeeping Closet 6076 - ACC	@ 11:11 AM - Excessive spraying of Aerosol activated alarm
148	055/2023	June 9, 2023	Fire Alarm	10:41 AM	10:41 AM	Tower Roof Corridor - DTS	@ 10:41 AM - Steam Leak activated alarm
149	056/2023	June 9, 2023	False Alarm	12:47 PM	12:49 PM	Basement Mechanical Room - CHSC	@ 12:47 PM -Defective device activated alarm - Replaced
150	057/2023	June 9, 2023	Fire Alarm	2:32 PM	2:32 PM	L1 Cafeteria - IOEC	@ 2:32 PM - Flammable refrigerant leak activated alarm
151	058/2023	June 10, 2023	Fire Alarm	11:07 AM	11:10 AM	Main Lobby - Penrose	@ 11:07 AM -Suspected insects might have activated alarm
152	059/2023	June 13, 2023	Fire Alarm	3:43 PM	3:43 PM	WW F2 Stair 2 floor Landing WFS - AUBMC	@ 3:43 PM - Activated water flow switch activated the alarm
153	060/2023	June 13, 2023	Fire Alarm	3:44 PM	3:46 PM	F1 Cashier - College Hall	@ 3:43 PM - Build-up dust might have activated alarm
154	061/2023	June 13, 2023	False Alarm	11:42 PM	11:44 PM	Sump pit Room B118 - IFI	@ 11:44 PM - Defective device activated alarm - Replaced
155	062/2023	June 14, 2023	Fire Alarm	12:05 PM	12:05 PM	Office W602 - AUBMC	@ 12:05 PM - generated fumes from a defectice AC unit
156		June 14, 2023	Fire Alarm	2:37 PM	2:37 PM	WW F1 Stair 2 floor Landing WFS - AUBMC	@ 2:37 PM - Activated water flow switch activated the alarm
157	063/2023	June 15, 2023	False Alarm	4:31 AM	4:33 AM	Basement Corridor - Pilot Plant	@ 4:31 AM - Defective smoke detector activated alarm - replaced
158	064/2023	June 16, 2023	False Alarm	6:16 AM	6:20 AM	Roof Mechanical Room - Laundry	@ 6:19 AM - Defective heat detector activated alarm - replaced
159	065/2023	June 19, 2023	False Alarm	1:34 AM	1:36 AM	Lab 405 - Chemistry	@ 1:34 AM - Defective heat detector activated alarm - Replaced
160	066/2023	June 19, 2023	False Alarm	7:58 AM	7:59 AM	Lab 405 - Chemistry	@ 7:58 AM - Defective heat detector' base activated alarm - Replaced
161	067/2023	June 19, 2023	Fire Alarm	12:06 PM	12:09 PM	Room 9032 - ACC	@ 12:06 PM - Deodorant Spray activated alarm
162	068/2023	June 20, 2023	Fire Alarm	7:31 AM	7:32 AM	Cashiers' Office 105 - College Hall	@ 7:31 AM - Build-up dust might have activated alarm
163	069/2023	June 20, 2023	Fire Alarm	11:13 AM	11:14 AM	Room 015 - Biology	@ 11:13 AM - Fumes from Overheated food item on hotplate activated alarm
164	070/2023	June 20, 2023	Fire Alarm	1:23 PM	1:24 PM	F2 Corridor - Building 37	@ 1:23 PM - Fumes from overheated food item in Microwave activated alarm
165	071/2023	June 24, 2023	Fire Alarm	11:34 AM	11:36 AM	F324 Corridor - West Hall	@ 11:34 AM - Suspected dust build-up might have activated alarm
166	072/2023	June 25, 2023	Fire Alarm	10:00 AM	10:03 AM	F4 Corridor - Chemistry	@ 10:00 AM - Dust generated by contractor activated alarm

ERT Log

July 1, 2022 - June 30 2023

#	Ref. #	Date	Type	Time	Response	Location	Cause
167	073/2023	June 27, 2023	Fire Alarm	12:22 PM	12:23 PM	Equipment Room 334 - West Hall	@ 12:22 PM - Fumes generated from burning a potato head in Mirowave activated alarm
168	074/2023	June 27, 2023	Fire Alarm	1:43 PM	1:44 PM	Room 334 - OSB	@ 1:43 PM - Two studets tampered with the MCP and activated the alarm
169	075/2023	June 28, 2023	False Alarm	3:36 PM	3:38 PM	Room 421b - Chemistry	@3:36 PM - Defective combined detector activated alarm - Replaced
170							